

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT
PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE REGULATION
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N° 24-01620 L

And 1 Appendix of 6 pages

MATERIAL presented by:

Vescom B.V.
Sint Josefstraat 20
5753 AV Deurne
Netherlands

TRADE NAME:

FUGA

BRIEF DESCRIPTION:

Fabric 100 % inherent fire resistant polyester

Nominal surface weight : 598 g/m²

Nominal thickness : 1.9 mm

Colours : Light grey

TEST REPORT :

N° 24-01620 E1V1 on the July 12nd 2024

TESTS :

Electrical burner test
Flame persistence test
Dripping test

CLASSIFICATION

M1

**Classification valid for any application for which the product is not subjected
to the CE marking of the Construction products**

CLASSIFICATION DURATION (article 5 of appendix 2) :

unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the July 12nd 2024



Olivier PALLAS
Tests and Trials Engineer